



CL-1B (CRUSHED STONE GRADATION CA-6)
MATERIAL BEDDING SHALL BE COMPACTED TO A
MINIMUM OF 95% IN ACCORDANCE WITH ASTM
2321-89

N.S.W.R.D. SANITARY SEWER
PIPE BEDDING DETAIL

NOT TO SCALE